DECLARATION OF CONFORMITY

Compatibility for all A2L Refrigerants

1111))

珂II)

....((111)

....III

1111

1111

1001)

1

呵)

1

....[]]

11111

III)

画))

TYPE OF EQUIPMENT: Two Stage Vacuum Pumps

((()))

MODEL NUMBER(S): 90063-2V-220, 90066-2V-220, 90068-2V-220, 90612-2V-220, 90063-2V-220SVB, 90066-2V-220SVB, 90612-2V-220SVB

	90063-2V-220-B	90066-2V-220-B	90068-2V-220-B	90612-2V-220-B
	90063-2V-220SVB	90066-2V-220SVB	90068-2V-220SVB	90612-2V-220SVB
No. of Stages	2	2	2	2
Free Air Displacement	85 lit/min,	170 lit/min,	227 lit/min,	340 lit/min,
	71 lit/min	142 lit/min	189 lit/min	283 lit/min
Ultimate Vacuum	15 microns	15 microns	15 microns	15 microns
Pump Motor	1/3 HP	1/2 HP	3/4 HP	1 HP
Pump Speed	1440 RPM	1440 RPM	1440 RPM	1440 RPM
Electrical Specs	110/220V,	110/220V,	110/220V,	110/220V,
	50/60 Hz	50/60 Hz	50/60 Hz	50/60 Hz

THIS DECLARATION CONFIRMS THE ABOVE EQUIPMENT HAS BEEN APPROVED FOR USE WITH ALL A2L REFRIGERANTS.

This equipment is being processed and supplied in accordance to our quality management systems and we hereby certify that the items detailed above comply in every respect with the requirements set forth by Mastercool Inc.

- The above items are in compliance with all SAE and EPA standards
- All components of this product have been tested and calibrated in our warehouse with a certified calibration vacuum source

MANUFACTURER'S NAME: Mastercool Inc., One Aspen Drive, Randolph, NJ 07869 USA

I, the undersigned, hereby declare that the equipment specified above conforms to the above Standard(s).

Place: One Aspen Drive Randolph, NJ 07869

Signature:

Full Name: Idean Barjesteh

Date: April 5, 2022 Position: International Sales Manager



(((O)))<u>\$</u>(((O)))<u>\$(((O)))</u>\$(((O)))